



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

August 15, 2006 **RE-ISSUED 9/02/2008**

N.E.W. TANKS, INC
EDWARD P. PAKANICH JR.
4923 LADE BEACH RD
LITTLE SUAMICO WI 54141

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: N.E.W. TANKS, INC
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1000 GAL.
(37" L.L., 26.7 GAL/IN., 48" MAX. DEPTH OF BURY, 473 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20060338

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When a department approved effluent filter is installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance or baffle shall be installed in the outlet of the septic tank or compartment.
- This product is approved to use the following:
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - PolyLok tank riser model 3008 and 3008-RC.
 - PolyLok 5, clampable boot seal for pipe openings.

This approval supersedes the approval issued on 8/15/2006 under product file number 20050219.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050219.

N.E.W. TANKS, INC
Page 2
August 15, 2006
Product File No:20060338

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov